

CERTIFICATE OF COMPLIANCE

Certificate Number 20170606-E10514
Report Reference E10514-19741119
Issue Date 2017-JUNE-06

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This is to certify that
representative samples of**

CONDUIT FITTINGS FOR USE IN HAZARDOUS
LOCATIONS

Adapters - Cat. Nos. ADUP followed by -01 or -12, conduit size 1/2 and 3/4 in. and Reducing Bushings: R or RE followed by -21, -31, -32, -41, -42, -43, -51, -52, -53, -54, -61, -62, -63, -64, -65, -73, -74, -75, -76, -83, -84, -85, -86, -87, -96, -97, -98, -106, -108, or -109, may be followed by S, conduit size 1/2 in to 4 in. for use in hazardous locations, Class I, Groups A, B, C and D; and Class II, Groups E, F and G.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

Standard No. UL 50 E, Enclosures for Electrical Equipment, Environmental Considerations

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

