

CERTIFICATE OF COMPLIANCE

Certificate Number 20120514- E344596
Report Reference E344596 - 20090531
Issue Date 2012-MAY-14

Issued to: NUOVA ASP SRL
VIA DE GASPERI 26
20090 PANTIGLIATE MI ITALY

**This is to certify that
representative samples of**

ENCLOSURES FOR USE IN HAZARDOUS LOCATIONS

Models EJB-21-UL, EJB-31-UL, EJB-51-UL, EJB-61-UL, EJB-63-UL Explosion-proof enclosures for use in Hazardous Locations, Class I, Groups B, C, and D; Class II, Groups E, F, and G; Class III.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle; with the word "CLASSIFIED"  (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

